

**DETROIT HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH & SAFETY
FIELD INVESTIGATION REPORT**

RESIDENT/BUSINESS NAME: MASON

ADDRESS: 19955 FENLON

COMPLAINANT: Referral from BSEED

PHONE:

TYPE OF INVESTIGATION:

Air Quality	<u> </u>	Hazardous Waste	<u> </u>
Environmental	<u>✓ </u>	Solid Waste	<u> </u>

OTHER:

NATURE OF COMPLAINT: DETROIT PUBLIC SCHOOLS/ Potential health-related violations observed by BSEED inspectors

DATE OF INSPECTION: 1/26/16

INVESTIGATION SUMMARY: An environmental health inspection was conducted at Mason Academy. Representatives from the Detroit Health Department-Environmental Health and Safety were there to assess the over-all environmental health and safety conditions of this DPS school facility.

Findings and Recommendations

1. Restore water to inoperable sink in the girl's restroom within 30 days.
2. Replace cracked door glass on gym door within 30 days.
3. Remove stains from ceiling tiles and replace broken ceiling tiles throughout the building within 30 days.
4. Provide a roof inspection from a 3rd party certified contractor within 72 hours.
5. Remove mold found on ceiling tiles within 72 hours.
6. Provide an air quality inspection from a 3rd party certified contractor within 72 hours.
7. Repair protective glass from fire pull and replace missing fire extinguisher within 72 hours.
8. Failure to conduct repairs within a timely manner will result in a recommendation of facility closure and the revocation of Certificate of Occupancy from the Detroit Health Department. Health Department representatives will follow up in 72 hours for roof inspection, mold removal and air quality inspection, and 30 days for other violations.

CONDUCTED BY: City of Detroit Environmental Team **Date:** 1/26/16

ROUTINE	Phone COMPLAINT	REFERRAL ✓
----------------	------------------------	----------------------



CONDUCTED BY: City of Detroit Environmental Team Date: 1/26/16

ROUTINE	Phone COMPLAINT	REFERRAL √
---------	-----------------	---------------